

certificate

The applicant:

**ROSCO IBERICA,S.A.**  
Calle del Oro 76 pol ind Sur  
28770 COLMENAR VIEJO - MADRID

is authorized to place the label " Certificate of curtains fire behaviour "  
according to the report Nº 2008AN0776



**aitex**

**CERTIFICATE OF FIRE  
BEHAVIOUR OF:**

**CURTAINS**

**Nº 08AN0776**

The sample reference:

**"ROSCOTEX MOLTON"**



has been tested according to the standards UNE EN 1101:1996 and  
UNE EN 13772:2003. The classification according to standard UNE EN  
13773:2003 is:

**"CLASS 1"**

This certificate has validity until the February 19th 2013  
Alcoy, February 20th 2008.



Silvia Devesa Valencia  
LABORATORIES ASSISTANT MANAGER



Raquel Muñoz González  
CHIEF OF LABORATORIES AREA

